

Light Measurement Report

Print date: 2-6-2025

Measurement date and time: 2-6-2025 13:57:20 – Measurement no. VFR-250602-1506-MS

Measurement tracking No. and Link: [VT250602-005110](#)

Operator:



Laboratory and Equipment

Laboratory Owner and Location

Goniospectrometer System and Type

Sensor Name, Calibr. Date and Serial No.

Spectrometer Manufacturer and Model

Viso Systems, Copenhagen V, Denmark

LabSpion – Type C, horizontal

LabSensor Model2 – 11-1-2024 – 3130191315

Ibsen Photonics, Denmark – Freedom VIS (Custom Viso)

Measurement Conditions

Number of C-planes and Resolution

γ (gamma)-Resolution

Test Distance

Input Power, Power and Displ. Factors

Input RMS Voltage and Current

Frequency of Input Power

Warm-up Time and Variation

32 planes – 11,25°

5°

10,10 m

24,9 W – PF 0,91 – DPF 0,92

230 V – 0,118 A

50 Hz

Lamp stabilized in 15 min 1 sec – 2,0%

Tested Light Source

Product Name

Item No. and Manufacturer

Product Description (line 1)

RL1-24-2700K

RL1-24-2700K – Dutchfulfillment

MI-LIGHT WALL WASHER 24W RGB+CCT

Main Light Measurement Results

Output – Total Lumen (Up% / Down%)

Efficiency

Peak Intensity and Beam Angle

Correlated Color Temperature, Target/Measured

Color Rendering Index

Color Rendering TM30-18

Color Shift, CIE duv and MacAdam Steps

Flicker

1676 lm – 0,91% / 99,09%

67 lm/W

1887 cd – 44,7°



CCT = 2700 K / 2755 K

CRI 83,0

R_f 85,2 – R_g 97,0

Duv -0,0006 – SDCM 2,5

SVM 0,01 – PstLM 0,03



Light Measurement Report

Print date: 2-6-2025

Measurement date and time: 2-6-2025 13:57:20 – Measurement no. VFR-250602-1506-MS


Measurement tracking No. and Link: [VT250602-005110](#)

Operator:



Luminous Intensity diagram

Unit: 0-100% of peak intensity



Main Values

Output (total Lumen)	1676 lm
Lumen Up% / Down%	0,91% / 99,09%
Peak Intensity	1887 cd
Beam Angle (50%)	44,7°
Beam Angle (90%)	48,3°
Beam Angle (10%)	44,7°

Cut-off Angle

Average 2,5%	145,5°
--------------	--------

Field Angle

Average 10%	103°
-------------	------


Intensity Ratio

In 120° cone	91,0%
In 90° cone	77,3%

C000-C180

C090-C270

Linear distribution diagram - Intensity (candela) vs γ-angle




Light Measurement Report


Print date: 2-6-2025
Measurement date and time: 2-6-2025 13:57:20 – Measurement no. VFR-250602-1506-MS
Measurement tracking No. and Link: [VT250602-005110](#)
Operator:



Iso-intensity Diagram (Iso-candela)



Iso-illuminance Diagram (Iso-lux)



Light Measurement Report

Print date: 2-6-2025

Measurement date and time: 2-6-2025 13:57:20 – Measurement no. VFR-250602-1506-MS

Measurement tracking No. and Link: [VT250602-005110](#)

Operator:




Color details


Correlated Color Temperature, Target CCT = 2700 K
Correlated Color Temperature, Measured CCT = 2755 K
Color Rendering Index CRI 83,0
Color Rendering Index, R9 (red component) R9 = 6,8
Color Rendering TM30-18 R_f 85,2 – R_g 97,0
Color Quality Scale CQS = 82,2

MacAdam Steps
Color coordinates CIE 1931 (x;y) = (0,460;0,411)
Color coordinate CIEs 1960 (u;v) = (0,263;0,352)
Color deviation from BBL Duv = -0,0006
Color coordinate CIEs 1976 (CIELUV) (u';v') = (0,263;0,527)


CIE 1931



CIE 1931 – zoomed on Planckian locus




Color Rendering Index per reference color (CIE 1995)




CRI R values, only R1-R8 are used to calculate final CRI value

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
81,7	91,8	95,6	81,9	82,3	91,4	81,5	57,4	6,8	82,2	83,0	77,2	84,2	98,3	72,7

Spectral power distribution (SPD) / W/nm – 0-100%




TM30-18 Rf-values per hue bin



TM30 C values, 16 binned values out of total of 99 C values

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
80,0	81,0	77,8	88,5	92,9	91,5	85,8	93,7	90,3	87,5	84,3	85,4	86,6	79,6	82,8	76,7

Color Quality Scale by reference color



CQS Q values

Q1	Q2	Q3	Q4	Q5	Q6	Q7	Q8	Q9	Q10	Q11	Q12	Q13	Q14	Q15
75,8	94,1	84,4	82,6	84,6	84,1	83,3	85,1	94,1	89,8	86,9	83,6	82,1	70,8	72,3

Light Measurement Report

Print date: 2-6-2025


Measurement date and time: 2-6-2025 13:57:20 – Measurement no. VFR-250602-1506-MS

Measurement tracking No. and Link: [VT250602-005110](#)

Operator:



Beam Details



Beam intensities from 1 – 20 m

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	m
3,3	6,6	9,8	13,1	16,4	19,7	23	26,2	29,5	32,8	36,1	39,4	42,7	45,9	49,2	52,5	55,8	59,1	62,3	65,6	ft
1841	460	205	115	74	51	38	29	23	18	15	13	11	9	8	7	6	6	5	5	lux
171,1	42,8	19	10,7	6,8	4,8	3,5	2,7	2,1	1,7	1,4	1,2	1	0,9	0,8	0,7	0,6	0,5	0,5	0,4	fc

Intensities in 0° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°	γ
1841	1779	1586	1329	1064	828	634	483	366	277	213	171	142	114	86	57	31	12	3	2	cd
100%	97%	86%	72%	58%	45%	34%	26%	20%	15%	12%	9%	8%	6%	5%	3%	2%	1%	0%	0%	of 0°val

Intensities in 90° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°	γ
1841	1811	1680	1442	1151	882	667	503	378	283	210	157	116	83	56	37	23	13	5	2	cd
100%	98%	91%	78%	63%	48%	36%	27%	21%	15%	11%	9%	6%	4%	3%	2%	1%	1%	0%	0%	of 0°val

Intensities in 180° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°	γ
1841	1779	1586	1329	1064	828	634	483	366	277	213	171	142	114	86	57	31	12	3	2	cd
100%	97%	86%	72%	58%	45%	34%	26%	20%	15%	12%	9%	8%	6%	5%	3%	2%	1%	0%	0%	of 0°val

Intensities in 270° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°	γ
1841	1811	1680	1442	1151	882	667	503	378	283	210	157	116	83	56	37	23	13	5	2	cd
100%	98%	91%	78%	63%	48%	36%	27%	21%	15%	11%	9%	6%	4%	3%	2%	1%	1%	0%	0%	of 0°val

Light Measurement Report

Print date: 2-6-2025

Measurement date and time: 2-6-2025 13:57:20 – Measurement no. VFR-250602-1506-MS

Measurement tracking No. and Link: [VT250602-005110](#)

Operator:



Light Planning – UGR table

Uncorrected, comprehensive UGR table according to 117-1995

Reflectances											
	ρ Ceiling	70	70	50	50	30	70	70	50	50	30
	ρ Walls	50	30	50	30	30	50	30	50	30	30
	ρ Floor	20	20	20	20	20	20	20	20	20	20
Room size											
H = mounting height above eye level											
X	Y	Viewed Crosswise (Viewing direction orthogonal to lamp length axis)					Viewed Endwise (Viewing direction parallel to lamp length axis)				
2H	2H	18,3	19,1	18,4	19,4	19,6	18,1	19,0	18,3	19,3	19,5
	3H	19,2	20,1	19,6	20,4	20,6	18,7	19,6	19,1	19,9	20,1
	4H	19,6	20,5	20,0	20,7	21,0	18,9	19,9	19,4	20,1	20,4
	6H	19,9	20,6	20,2	20,9	21,3	19,2	20,0	19,5	20,3	20,7
	8H	19,9	20,6	20,2	21,0	21,4	19,3	20,0	19,6	20,4	20,8
	12H	19,9	20,6	20,2	21,0	21,4	19,3	20,1	19,7	20,4	20,9
4H	2H	18,4	19,3	18,8	19,6	19,8	18,3	19,2	18,7	19,4	19,7
	3H	19,6	20,3	20,0	20,7	21,1	19,1	19,8	19,5	20,2	20,6
	4H	20,0	20,7	20,4	21,1	21,6	19,4	20,0	19,8	20,5	21,0
	6H	20,3	20,9	20,8	21,3	21,7	19,6	20,3	20,1	20,7	21,0
	8H	20,3	20,9	20,8	21,3	21,7	19,7	20,3	20,3	20,7	21,1
	12H	20,3	20,8	20,8	21,2	21,7	19,8	20,3	20,3	20,7	21,2
8H	4H	20,0	20,6	20,5	21,0	21,3	19,4	20,0	19,9	20,4	20,8
	6H	20,3	20,8	20,8	21,2	21,8	19,7	20,2	20,2	20,6	21,2
	8H	20,4	20,8	21,0	21,3	22,0	19,9	20,3	20,4	20,8	21,5
	12H	20,5	20,8	21,1	21,3	21,9	20,0	20,4	20,6	20,9	21,5
12H	4H	19,9	20,4	20,4	20,9	21,3	19,4	19,9	19,9	20,3	20,8
	6H	20,3	20,7	20,9	21,2	21,9	19,8	20,1	20,3	20,6	21,3
	8H	20,4	20,7	21,0	21,2	21,9	19,9	20,2	20,5	20,7	21,3
Variations with the observer position for the luminaire spacings, S:											
S = 1.0H		0,4 / -0,5					0,5 / -0,5				
S = 1.5H		1,1 / -1,0					1,3 / -1,1				
S = 2.0H		1,9 / -1,7					2,2 / -1,9				

Coefficients of Utilization

Ceiling reflectance	80			70			50			30			10			0		
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR		(RCR: Room Cavity Ratio)			Room Values are expressed as percentage of Lumen delivered to the task surface													
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	101	101	101	99
1	112	108	105	102	109	106	103	100	101	99	97	97	96	94	94	92	91	89
2	104	98	93	89	102	96	92	88	93	89	86	90	86	84	87	84	82	80
3	98	90	83	78	95	88	82	78	85	80	76	82	78	75	80	77	74	72
4	91	82	75	70	89	81	75	70	78	73	69	76	72	68	74	70	67	65
5	86	76	69	64	84	75	68	63	73	67	63	71	66	62	69	65	61	59
6	81	70	63	58	79	69	63	58	68	62	57	66	61	57	65	60	56	55
7	76	65	58	53	75	65	58	53	63	57	53	62	56	52	61	56	52	50
8	72	61	54	49	71	60	54	49	59	53	49	58	53	49	57	52	48	47
9	68	57	51	46	67	57	50	46	56	50	46	55	49	46	54	49	45	44
10	65	54	47	43	64	54	47	43	53	47	43	52	46	43	51	46	42	41

Light Measurement Report


Print date: 2-6-2025
Measurement date and time: 2-6-2025 13:57:20 – Measurement no. VFR-250602-1506-MS
Measurement tracking No. and Link: [VT250602-005110](#)
Operator:



Luminaire budgetary diagram

Uncorrected, comprehensive UGR table according to 117-1995

LAMPS (number of lamps)



Conditions

H = Room height	Flux = 1676 lm	p(%)		
H _{down} = Lamp distance from ceiling =	0.00 m	Line type	Ceiling reflectance	Wall reflectance
H _{work} = Work area height from floor =	0.00 m	-----	70	50
E _{work} = Average lux on work area =	100 lx	_____	50	30
				Floor reflectance
				20

Zonal Lumen Summary

0°-10°	10°-20°	20°-30°	30°-40°	40°-50°	50°-60°	60°-70°	70°-80°	80°-90°
163 lm	365 lm	366 lm	290 lm	205 lm	137 lm	85,5 lm	40,6 lm	10,3 lm
90°-100°	100°-110°	110°-120°	120°-130°	130°-140°	140°-150°	150°-160°	160°-170°	170°-180°
1,89 lm	1,79 lm	1,92 lm	2,14 lm	2,18 lm	2,06 lm	1,73 lm	1,18 lm	0,415 lm

Light Measurement Report

Print date: 2-6-2025

Measurement date and time: 2-6-2025 13:57:20 – Measurement no. VFR-250602-1506-MS

Measurement tracking No. and Link: [VT250602-005110](#)

Operator:



Outdoor Light Planning

Lumen per Zone

Zone (γ)	Lumen	% Total
0-10°	163 lm	9,7%
10-20°	365 lm	21,8%
20-30°	366 lm	21,8%
30-40°	290 lm	17,3%
40-50°	205 lm	12,2%
50-60°	137 lm	8,1%
60-70°	85 lm	5,1%
70-80°	41 lm	2,4%
80-90°	10 lm	0,6%
90-100°	2 lm	0,1%
100-110°	2 lm	0,1%
110-120°	2 lm	0,1%
120-130°	2 lm	0,1%
130-140°	2 lm	0,1%
140-150°	2 lm	0,1%
150-160°	2 lm	0,1%
160-170°	1 lm	0,1%
170-180°	0 lm	0,0%
Total	1676 lm	100,0%

Intensity peaks

Max intensity	1887 cd
Intensity, 90°	3 cd
Intensity, 0°	1841 cd

Zonal Lumen summary

Zone (γ)	Lumen	% Total
0-30°	893 lm	53,3%
0-40°	1183 lm	70,6%
0-60°	1524 lm	91,0%
60-90°	136 lm	8,1%
70-100°	53 lm	3,1%
90-120°	6 lm	0,3%
0-90°	1661 lm	99,1%
90-180°	15 lm	0,9%
0-180°	1676 lm	100,0%


BUG rating

	Lumen	% Total
Forward light		
Low(0-30°)	447 lm	26,7%
Medium(30-60°)	316 lm	18,9%
High(60-80°)	63 lm	3,8%
Very high(80-90°)	5 lm	0,3%
Back light		
Low(0-30°)	447 lm	26,7%
Medium(30-60°)	316 lm	18,8%
High(60-80°)	63 lm	3,8%
Very high(80-90°)	5 lm	0,3%
Uplight		
Low(90-100°)	2 lm	0,1%
High(100-180°)	13 lm	0,8%

IESNA TM-15-07

Luminaire Classification System For Outdoor Luminaires

BUG rating B1 U2 G0



Light Measurement Report

Print date: 2-6-2025
Measurement date and time: 2-6-2025 13:57:20 – Measurement no. VFR-250602-1506-MS
Measurement tracking No. and Link: [VT250602-005110](#)
Operator:




Power Details


Input Power

Power feed to light source	24,9 W
Frequency of input power	50 Hz
RMS Input voltage feed, V_{RMS}	230 V
RMS Input current feed, I_{RMS}	0,118 A
Volt-Ampere or apparent power = $V_{RMS} * I_{RMS}$	27,23 VA
Displacement factor of AC power feed	0,92
Power factor of AC current feed	0,91
Total harmonic distortion of the current	8,5%
Total harmonic distortion of the voltage	0,07%

Input Power Curve



Efficiency



Stabilization Details

Warmup Conditions

Stable period	15 min
Stable change max	2,0%
Minimum time	15 min

Color Temperature Change

CCT start	2699 K
CCT shift	+1 K
CCT end	2700 K


Warmup Result

Total warmup time	Lamp stabilized in 15 min 1 sec
Warmup variation	-1,4%

Output Change

Output start	1699 lm
Output change	-23 lm
Output end	1676 lm

Stabilization Curve



Light Measurement Report


Print date: 2-6-2025
Measurement date and time: 2-6-2025 13:57:20 – Measurement no. VFR-250602-1506-MS
Measurement tracking No. and Link: [VT250602-005110](#)
Operator:



Flicker /TLA details

Flicker Meter Type	Viso Systems LabFlicker	Measurement time	
Frequency of input power	50 Hz	PstLM	180 sec
Flicker/TLA sample rate	20000 samples/s	All other indices	1,2 sec
Flicker indices according to Illuminating Engineering Society (IES)		Flicker indices according to California Energy Commission (CEC) 2016b	
Flicker frequency	100 Hz	JA8/10 40 Hz	0,01 %
Percent Flicker	0,76 %	JA8/10 90 Hz	0,02 %
Flicker index	0	JA8/10 200 Hz	0,21 %
		JA8/10 400 Hz	0,32 %
		JA8/10 1000 Hz	0,51 %
TLA indices (re IEC TR 61547-1, IEC 61000-3-3 and IEC 61000-4-15)		Flicker indices according to Lighting Research Center (2015)	
PstLM value (F < 80 Hz)	0,03	Perception metric, Assist Mp	0,01
SVM value (80 < F < 2000 Hz)	0,01		

Flicker frame (frame of one flicker period in time domain)



Flicker FFT (flicker curve in frequency domain)



IEEE 1789 Frequency/modulation plot

